

Safety/Energy Committee Minutes
Held In-Person/Zoom Hybrid; June 13, 2023

Present: Allen Risen, Michelle Sides, Beeb Singson, Jessica Olson, Mark Lilley, Jacquyn Vasquez, Adria Henrickson, Mike Hanson, and Kristen Stevens.

Absent: Julie Grammer, Janelle Hampton, Zachary Hammerle, Rebecca Chiles, Mike Komes, Nora Solvedt, Mike McGlade, and Chelsee Blatner.

Meeting was called to order at 1401 hrs.

Review of Minutes:

- Allen Risen made the motion to approve, Mike Hanson seconded.
- May 13 minutes approved.

Building Fire life Safety Inspections: Allen Risen.

Trip Hazards Notes;

- Valsetz east outside elevator has sunken or missing light lenses in ground level sidewalk.
- Barnum Hall west upper lounge landing by south stairs has a missing chunk of cement causing potential trip hazard.
- Noble Hall west entrance in missing a section of floor carpet square causing a potential trip hazard when exiting through door.

Extinguisher Issues;

- Several buildings still not receiving their monthly extinguisher checks by building manager or assigned persons.
- I completed monthly check of extinguishers and initialed tags still needing signed off for June.
- Welcoming Center Fire Riser room, Sprinkler water pressure gauge arrow at zero. Advised Facilities of problem.

Fire Door Issues;

- Gentle House south exit door by kitchen blocked by chairs storage.

Emergency Lighting Issues;

- Landers Hall 3 emergency lights (2-upper and 1-lower lounge) not working.

Elevator Emergency Phones;

- Ackerman Hall both elevator emergency phones not working. Telecom advised and corrected.
- Welcoming Center east elevator emergency phone not working. Telecom advised and corrected.
- Parking Lot J emergency phone next to Sequoia Commons not working.

Electrical Issues;

- Welcoming Center 216 using an extension cord to power up a power-strip for computer.

Signage;

- Cedar Hall FDC (Fire Department Connection) sign needs raised at SE exterior corner. Can't read from street due to plant growth.

Ceiling Tile Missing/Holes Needing Closed;

- Heritage Hall Basement Mechanical room has a large 4'X4' openings cut in to wall needing closed.
- Ackerman hallway ceiling outside 142 has a 12x14 hole cut in ceiling for a past repair, needs closed.
- Valsetz hallway ceiling outside salad room 109 has large hole and needs closed/covered.

Injury Review: None this month.

Energy Conservation Update:

- No update this month.

Round Table:

- Allen will be retiring this month. Thank you for your dedication to keeping our campus safe!
- Three groundwater monitoring wells have been drilled near the cross-country track. The wells will be marked and sealed.
- Roof work is being done at the Welcome Center. Be cautious around the barricaded areas.

Next Meeting: July 18, 2023, 2pm, in Hamersly Library 205.
Meeting adjourned at 1425 hrs.